

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1521:123 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089  
Contact: Albert Badalpour (847) 215-1050

**DESIGN:** Models BPS10, BPS10C, BPS10220, EBPS6, BPS6C, EBPS6220, booster power supplies. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** EBPS6, -6C, EBPS10, -10C: 120 VAC  
EBPS6220, EBPS10220: 220 VAC

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All installations must be in accordance with NFPA 72, 1996 Edition.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as booster power supply for use with listee's separately listed compatible fire alarm control units to extend the notification appliances circuit.

**XLF:** 7300-1388:225

10-02-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 18, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager